

Burlington's Contractors RRP Final Checklist

*Name of Firm: _____

*Construction Permit #: _____

*Name of Assigned Renovator: _____

*Renovator's RRP Certification Number: _____

___ Copies of renovator and dust sampling technician qualifications (training certificates, certifications) on file.

___ Certified renovator provided training to workers on (check all that apply):

___ Posting warning signs

___ Setting up plastic containment barriers

___ Maintaining containment

___ Avoiding spread of dust to adjacent areas

___ Waste handling

___ Post-renovation cleaning

___ Test kits used by certified renovator to determine whether lead was present on components affected by renovation (identify kits used and describe sampling locations and results): _____

___ Warning signs posted at entrance to work area.

___ Work area contained to prevent spread of dust and debris

___ All objects in the work area removed or covered (interiors)

___ HVAC ducts in the work area closed and covered (interiors)

___ Windows in the work area closed (interiors)

___ Windows in and within 20 feet of the work area closed (exteriors)

___ Doors in the work area closed and sealed (interiors)

___ Doors in and within 20 feet of the work area closed and sealed (exteriors)

___ Doors that must be used in the work area covered to allow passage but prevent spread of dust

___ Floors in the work area covered with taped-down plastic (interiors)

___ Ground covered by plastic extending 10 feet from work area—plastic anchored to building and weighed down by heavy objects (exteriors)

___ If necessary, vertical containment installed to prevent migration of dust and debris to adjacent property (exteriors)

___ Waste contained on-site and while being transported off-site.

___ Work site properly cleaned after renovation

___ All chips and debris picked up, protective sheeting misted, folded dirty side inward, and taped for removal

___ Work area surfaces and objects cleaned using HEPA vacuum and/or wet cloths or mops (interiors)

___ Certified renovator performed post-renovation cleaning verification (describe results, including the number of wet and dry cloths used): _____

Signature below certifies under penalty of law that the above information is true and complete.

* Name and title

* Date

NOTE: 'Any consent given by the City of Burlington as a result of the issuance or subsequent closing of any building/construction permits, shall not exempt the certified firm or individual from any enforcement action by the United States Environmental Protection Agency ("US EPA") regarding the Renovation, Repair and Painting Rule ("RRP"), nor shall it be relied upon as compliance with the RRP in any such action by the US EPA.'